

RAVICHANDRAN, B.E., M.I.E., F.I.V.,

98424 33679,
Chartered Civil Engineer,
Reg.No. : 142574-3,
Approved Valuer FIV : 17204,
Structors Panel Engineer for Issuing
Structural Soundness Certificate (Class-1A)
Income Tax & Wealth Tax Reg.No. C/483/5/2011

Panel Valuer for Banks

- | | |
|--|---|
| <input type="radio"/> Union Bank of India | <input type="radio"/> Catholic Syrian Bank |
| <input type="radio"/> Canfin Homes Ltd., | <input type="radio"/> Tamilnadu Mercantile Bank |
| <input type="radio"/> Indian Overseas Bank | <input type="radio"/> Bank of Baroda |
| <input type="radio"/> LIC, HFL | <input type="radio"/> UCO Bank <input type="radio"/> DCC Bank |
| <input type="radio"/> PNB | <input type="radio"/> Bank of Maharashtra |
| <input type="radio"/> South Indian Bank | <input type="radio"/> State Bank of India |

Office : No.7, Vasavi Complex, LGB Compound 2nd Street, Near Bus Stand, Dindigul - 624 001.

Date : 15.04.2021

(Dindigul Dist Order No. R.Dis. 4137/2009/R4 Dt. 07.01.2011)


Ref : Board of Engineers Proceeding No. AEE/TI/AEII/50705/2010, Dt. 30.11.2010 – P.W.D –
Chepauk – Chennai – Govt of Tamil Nadu.

Sub : DLV PUBLIC SCHOOL(DREAMLAND VIDHYASHRAAM), - Dindigul – Natham Main
Road - Kanavaipatty Village & Panchayat – Dindigul East Taluk - Dindigul District - Structural
Stability Certificate.

I, Er. S.Ravichandran, has been requested by **DLV PUBLIC SCHOOL(DREAMLAND
VIDHYASHRAAM)**, - Dindigul – Natham Main Road - Kanavaipatty Village & Panchayat – Dindigul
East Taluk - Dindigul District to inspect their School Premises and issue necessary structural stability
certificate. The School building has been inspected by me on 15.04.2021 and found that the building is
structurally sound. The Structural stability certificate for the **DLV PUBLIC SCHOOL(DREAMLAND
VIDHYASHRAAM)**, is issued for the period from 02.05.2021 to 01.05.2024.

NOTE:

1. Any cracks develop in the structure in the said period should be brought to the notice of the panel Engineer.
2. The Structural soundness certificate will be revoked at any time if any defect is found during the said period.
3. The Panel Engineer reserve the right to inspect the **School Building** at working hours and if found any defects the structural soundness certificate may be revoked without assigning any reasons.
4. Damage due to Natural calamities like, Heavy rain, Storm, Earth Quake & Flood will not cover this certificate.
5. The building maintenance must be necessary


COLLECTOR'S PANEL ENGINEER

Er.S. RAVICHANDRAN, B.E., M.I.E., F.I.V.,
Chartered Civil Engineer & Approved Valuer
Panel Valuer For Banks
No. 7, Vasavi Complex, Near Bus Stand,
LGB Compound 2nd Lane,
DINDIGUL - 624 001. Cell 98424 33679

FORM - A

DLV PUBLIC SCHOOL(DREAMLAND VIDHYASHRAAM), - Dindigul - Natham Main Road -
Kanavaipatty Village & Panchayat - Dindigul East Taluk

STATEMENT ACCOMPANYING FORM (A)

1. Door No. of the Building : -
2. Location : Street / Ward No. : -
Name of the Place, i.e., Corporation/ Municipality / Panchayat union, Town ship / Contonment : S.No.81/9, Dindigul - Natham Main Road, Kanavaipatty Village & Panchayat, Dindigul East Taluk, Dindigul District.
3. Years of construction : 2018
Plinth area of Ground Floor - 1381.28 Sqm or 14868.09 Sqft
4. Approximate cost of construction As per Current rates : Rs.1,00,00,000/-
5. Purpose for which the building is Being used or proposed to be used : School Building
6. Purpose for which the building has in There to been used : School Building
7. Details of construction of the building (Particulars of the foundation soil, Specification of the various parts under
 - a) Foundation : R.C.C Footing & Plinth beam 1:2:4 mix
 - b) Basement : R.C.C Column & Plinth beam 1:2:4 mix
 - c) Superstructures : Brick work in Cement Mortar
 - d) Floor and roof are to be given: Cement flooring & R.C.C. Roof Slab
8. Period for which the license is required: 02.05.2021 to 01.05.2024
9. No. of persons to be accommodated : 600 Persons
- 9(a). "CERTIFIED" that no addition or alteration has been made to be existing or portion of a building for which this application has been made, I undertake to obtain a fresh license in case any addition or alteration is made to the existing or portion of building. I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of building or a portion of the building originally is changed or altered subsequently".

**SIGNATURE OF THE OWNER OF THE
BUILDING**


COLLECTOR'S PANEL ENGINEER
E.S. RAVICHANDRAN, B.E., M.E., F.I.V.,
Chartered Civil Engineer & Approved Valuer
Panel Valuer For Banks
No. 7, Vasavi Complex, Near Bus Stand,
LGE Compound 2nd Lane,
DINDIGUL 624 001 Cell 98424 33679

FORM - B

P.L.V PUBLIC SCHOOL(DREAMLAND VIDHYASHRAAM), - Dindigul - Natham Main Road -
Kanavaipatty Village & Panchayat - Dindigul East Taluk

FORM of Certificate of structural soundness under sub-section 4 of the Tamilnadu Public building (Licensing) Act 1965 (Tamilnadu Public Buildings (Licensing) Rules 1966.

I certify that I have inspected the building mentioned in the Statement and furnished below the salient technical features.

1. FOUNDATION :

- | | | | |
|----|---|---|----------------|
| a. | Depth below ground level | : | 7ft |
| b. | Nature of soil met with at foundation: | | Gravel |
| c. | Pressure at foundation | : | 0.40T/sft |
| d. | Probable safe bearing capacity of the
Strata met with foundation | : | 3 to 3.5 T/sft |

2. SUPER STRUCTURES :

- | | | | |
|----|--|---|------------------------------|
| a. | Maximum stress in the most critical
Section of masonry and concrete | : | 0.75 T/sft |
| b. | Nature of masonry and concrete and
its safe permissible stress | : | Brick work for C.M. 10 T/sft |

The Structural soundness of the building has been verified by me with reference to ISI loading Standard 875 (Latest version) and other relevant is code of practice and I declare that the Building is structurally sound to be used as public building for the purpose noted in the Statement a Licence may be granted for the period from 02.05.2021 to 01.05.2024 (Three years) subject to Regular instance.


COLLECTOR'S PANEL ENGINEER

Er.S. RAVICHANDRAN, B.E., M.E., F.I.V.,
Chartered Civil Engineer & Approved Valuer
Panel Valuer For Banks
Ee.V. Vasavi Complex, Near Bus Stand,
LGE Compound 2nd Lane,
DINDIGUL 624 001 Cell 98424 33679

FORM - C

DLV PUBLIC SCHOOL(DREAMLAND VIDHYASHRAAM), - Dindigul - Natham Main Road -

Kanavaipatty Village & Panchayat - Dindigul East Taluk

STATEMENT TO ACCOMPANYING CERTIFICATE OF STRUCTURALLY SOUNDNESS

Location of the building Door No./place	Age of the building	No. of storey	Short description structure steel Rec framed of Load bearing	The purpose for which the building is certified for Use	The period for which the building will be structurally sound	No. of persons to be accommodated
DLV Public School (Dreamland Vidhyashraam), S.No.81/9, Dindigul - Natham Main Road, Kanavaipatty Village & Panchayat, Dindigul East Taluk, Dindigul District.	G.F. - 3 yrs	Ground, Floor only	R.C.C Footing & Column with Plinth beam, Brick work in C.M Mix, R.C.C Roof, Cement Floor	School Building	3 Years 02.05.2021 to 01.05.2024	600 Persons

S. S. Ravi Chandran
COLLECTOR'S PANEL ENGINEER


Dr. S. RAVICHANDRAN, B.E., M.E., P.E.,
Chartered Civil Engineer & Approved Valuer
Panel Valuer For Banks
No.7, Vasanvi Complex, Near Bus Stand,
LOB Co-operative 2nd Lane,
DINDIGUL. 624 001. Call 98424 33679

FORM - D
DECLARATION

S. RAVICHANDRAN, residing at No.7, Vasavi Complex, L.G.B Compound, 2nd Street, Dindigul, hereby declare that I possess the Qualification and experience specified in the Table to Rule II of the Madras Public Building (Licensing) Rules 1966 for issuing of the Certificate of Structural soundness of the building covered by the certificate.


Place : Dindigul

Date : 15.04.2021


COLLECTOR'S PANEL ENGINEER

E.S. RAVICHANDRAN, B.E., M.I.E., F.I.V.,
Chartered Civil Engineer & Approved Valuer
Panel Valuer For Banks
No. 7, Vasavi Complex, Near Bus Stand,
LGB Compound 2nd Lane,
DINDIGUL 624 001 Cell 98424 33679

- | | | | |
|----|---|---|---|
| 1. | Name & Address | : | S. RAVICHANDRAN, B.E., M.I.E., F.I.V.,
No.7, Vasavi Complex, L.G.B Compound,
2 nd Street, Dindigul - 1. |
| 2. | Engineering Qualification | : | Degree holder in Bachelor of Engineering
(Madurai Kamaraj University) 1991 B.E.,
Member in the Institutions of Chartered
Engineering and Valuers. |
| 3. | No. of years of Experience &
Nature there of | : | 30 years of Experience in Chartered Engineering
and consulting Engineers.
Panel Valuer of LIC., & Banks, Competent person-
inspector of factories. |



COLLECTOR'S PANEL ENGINEER
(Dindigul Dist Order No. R. Dis.4137/2009/R4 Dt. 07.01.2011)

E.S. RAVICHANDRAN, B.E., M.I.E., F.I.V.,
Chartered Civil Engineer & Approved Valuer
Panel Valuer For Banks
No. 7, Vasavi Complex, Near Bus Stand,
LGB Compound 2nd Lane,
DINDIGUL 624 001 Cell 98424 33679

FORM - E

Form of report to be made to the competent authority to Inspection authorized of officers appointed under other Acts under section 28 of the Madras Public Building (Licensing Act 1963) Madras Act 13 of 1965 referred to in rule 7 of the Madras Public Building (LICENSING RULES 1968).

1. Name and Designation if Inspecting : S. RAVICHANDRAN, B.E., M.I.E., F.I.V.,
Authority or officer appointed or having : No.7, Vasavi Complex, L.G.B Compound,
Jurisdiction under any other : 2nd Street, Dindigul - 1.
2. Location (Street No. Ward No) Name of Place: DLV Public School (Dreamland Vidhyashraam),
(i.e) Corporation/ Municipality/Panchayat : S.No.81/9, Dindigul - Natham Main Road,
Union/ Township/Contonment : Kanavaipatty Village & Panchayat,
Dindigul East Taluk,
Dindigul District.
3. Date of Inspection : 15.04.2021
4. Purpose for which the building is being used : School Building
5. Nature of defects noticed :
6. Suggestions for rectifying defects :
7. If in a dangerous condition immediate : Periodically maintenance should be taken.
Steps recommended to be taken


COLLECTOR'S PANEL ENGINEER

ET.S. RAVICHANDRAN, B.E., M.I.E., F.I.V.,
Chartered Civil Engineer & Approved Valuer
Panel Valuer For Banks
No.7, Vasavi Complex, Near Bus Stand,
LGB Compound 2nd Lane,
DINDIGUL - 624 001 Cell 99424 33679